



***CONDENSATE NEUTRALIZER MEDIA for the PROPP40-KIT, PROPP40,  
PROPP100, and PROPP-PUMP condensate neutralizers***

***INSTALLATION, OPERATION AND MAINTENANCE INSTRUCTIONS***

**Installation Instructions**

***NOTE - Check with your local water authority for regulations regarding discharge of treated condensate to the drain or sewer system.***

**⚠ WARNING:** This product can expose you to Silica, crystalline (airborne particles of respirable size) which is known in the state of California to cause cancer. For more information go to [www.P65Warnings.ca.gov](http://www.P65Warnings.ca.gov)

Remove the old neutralizing media and rinse the capsule clean. Pour the new neutralizing media into the capsule.

**Operation**

The appliance condensate will flow through the neutralizing media, raising the pH of the condensate to a level that will help prevent corrosion of the domestic drain and the public sewer system.

**Maintenance**

Monitor the level of the neutralizing media in the tank periodically. Check the pH level at the outlet of the neutralizing kit periodically and use a suitable pH test strip paper. The neutralizing media should be replaced when the pH level drops below the minimum level of the local water authority, or after one year, whichever comes first. For replacement media contact [fwwebb.com](http://fwwebb.com)