

ANODELESS METER RISERS



Specifications:

- Meets or exceeds all requirements for the Categorization of Mechanical Fittings within ASTM D2513-90c Category 1, and requirements from the Code of Federal Regulations, Title 49 part 192.281, 192.283 and 192.375.
- Meets or exceeds NFPA-58.
- Listed with IAPMO/UPC & CSA.
- Pipe Threads conform to ANSI B1.20.1.
- All Gas Carrying Steel parts meet or exceed ASTM A53.
- Casing Materials meet or exceed ASTM A 513.
- All polyethylene pipe and tubing components conform to ASTM D 2513.

SIZE (MPT X PE)	WALL	VERTICAL LENGTH	HORIZONTAL LENGTH	PART NUMBER	PART NUMBER with Con-Stab
1/2"MPT X 1/2"CTS (5/8" OD) PE	.090	30"	15"	1253-91-4604-00†‡	1253-91-4604-25†‡
3/4"MPT X 1/2"CTS (5/8" OD) PE	.090	18"	19"	1355-91-4604-00†‡	1355-91-4604-25†‡
3/4"MPT X 1/2"CTS (5/8" OD) PE	.090	30"	17"	1353-91-4604-00†‡	1353-91-4604-25†‡
3/4"MPT X 1/2"IPS PE	SDR-9.3 (.090)	30"	17"	1353-91-4612-00‡	1353-91-4612-25
3/4"MPT X 3/4"IPS PE	SDR-11 (.095)	30"	16"	1353-91-4613-00†‡	1353-91-4613-25†‡
3/4"MPT X 1"CTS (1 1/8"OD) PE	.099/.101	30"	16"	1353-91-4608-00†‡	1353-91-4608-25‡
1" MPT X 1"IPS PE	SDR-11 (.119)	30"	16"	1453-91-4614-00†‡	1453-91-4614-25†‡
1 1/4"MPT X 1 1/4"IPS PE	SDR-10 (.166)	30"	22"	1553-91-4615-00†‡	1553-91-4615-25†
1 1/4" MPT X 1 1/4"IPS PE	SDR-11 (.151)	30"	22"	1553-61-4615-0A†‡	9953-99-0503-25†
1 1/2"MPT X 1 1/2"IPS PE	SDR-11 (.173)	36"	26"	1652-91-4616-00†‡	1652-91-4616-25‡
2" MPT X 2"IPS PE	SDR-11 (.216)	36"	30"	1752-91-4617-00†‡	1752-91-4617-25†

- **For sizes not listed, contact Continental Industries.**
- Recommended accessories for Anodeless Meter Risers with Con-Stab ID Seal® Couplings;
 - Continental's Bladed Chamfering Tool. See below.
- Part numbers listed are for 2406 medium density polyethylene pipe. For part numbers with 3408 high density pipe, contact Continental Industries.
- † = CSA Approved / ‡ = IAPMO/UPC Listed



CONTINENTAL INDUSTRIES, INC.

4102 South 74th East Avenue / Tulsa, Oklahoma 74145
Phone 1-800-558-1373 / Fax 918-622-1275 / www.conind.com